

Certificate




for European Product Safety

Reference No. 1221946

Socket-outlet

Type designation	DGSz1CZ.2/..
Certificate holder	Kontakt-Simon S.A ul Bestwinska 21 PL-43-500 Czechowice-Dziedzice POLAND
The product complies with the standard(s)	IEC 60884-1:2002 and A1 SS 428 08 34:2004
Date of expiry	26 October 2017

Additional information in Appendix.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
Signed	 Håkan Eriksson	Date	25 October 2012 Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.

**Intertek**
Appendix


Reference No. 1221946

Technical data

Type designation	DGSz1CZ.2/..
Rated voltage (V)	250~
Rated current (A)	16
IP-Class	20
Standard sheet	CEE 7/III
Trade mark	 simon
Product information	Rewirable 1-fold socket-outlet of flush-type, with shutters, screwless terminals suitable for rigid (solid or stranded) and flexible conductors of 1.5 – 2.5 mm ² area.

Manufacturing site(s) Kontakt-Simon S.A
ul Bestwinska 21
PL-43-500 Czechowice-Dziedzice
POLAND

Certification Body Intertek Semko AB, Product Certification *Place* Kista - Stockholm

Signed 
Håkan Eriksson *Date* 25 October 2012

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.