

Certificate



Intertek

for European Product Safety

Reference No. 1122700

Room thermostat

Type designation DRT10Z.2/.., DRT10W.2/..

Certificate holder **Kontakt-Simon**
ul Bestwinska 21
PL-43-500 Czechowice-Dziedzice
POLAND

The product complies with the standard(s) EN 60730-1:2000 +A12+A13+A1+A14+A16+A2
EN 60730-2-9:2010

Date of expiry 18 April 2013


EU Directive information *The product satisfies the provisions for CE marking according to the Low Voltage Directive 2006/95/EC.*

Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification

Place Kista - Stockholm

Signed


Håkan Eriksson

Date 12 April 2012

Page 1 of 2

This certificate is issued in accordance with the terms and conditions set out in the Appendix.





**Intertek
Appendix**

Reference No. 1122700


Technical data

Type designation	DRT10W*2/**, DRT10Z*2/**
Rated Voltage (V)	230V AC
Rated Current (A)	16(2)A
Class	I
IP-Class	20
Number of cycles	Relay: 100000 cycles (A). Main switch: 10000 cycles (M, A)
Purpose	Independently mounted room thermostat
Features of automatic action	1.B (micro-disconnection)
Method of connection	Screw terminals for fixed wiring.
Product information	Category D. Material Group IIIa (PTI175). Pollution situation 2. U _{imp} 4,0 kV. Overvoltage category III.
Others	DRT10W*2/**: with internal sensor. DRT10Z*2/**: with external sensor cable.
Manufacturing site(s)	Kontakt-Simon ul Bestwinska 21 PL-43-500 Czechowice-Dziedzice POLAND

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the products according to the Low Voltage Directive 2006/95/EC.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed


Håkan Eriksson

Date 12 April 2012

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.